MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION	
North Hinds Water Supply Name	
Public Water Supply Name	
250011 - 250009 - 250094 - 250015 - 250029	
List PWS ID #s for all Community Water Systems included in this CCR	 .

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
 □ Advertisement in local paper (attach copy of advertisement) □ On water bills (attach copy of bill) □ Email message (MUST Email the message to the address below) □ Other
Date(s) customers were informed: Co/29//5 , / / , / /
CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used U.S. Postal Service
Date Mailed/Distributed: 06/29/15
CCR was distributed by Email (MUST Email MSDH a copy) Output Date Emailed: / / As a URL (Provide URL
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
· · · · · · · · · · · · · · · · · · ·
Name of Newspaper:
CCR was posted in public places. (Attach list of locations) Date Posted: / /
CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):
CERTIFICATION I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply. **Docume Consumer Confidence Report (CCR) has been distributed to the customers of this public water system distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply. **Docume Consumer Confidence Report (CCR) has been distributed to the customers of this public water system of the customers of

Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

May be faxed to: (601)\$76-7800

May be emailed to: water.reports@msdh.ms.gov

North Hinds Water Assn., 2014 0260684 CCR 05/17/2016

is my water sele?

North Hinds Water assn. is pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautious?

Some peoplo may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infectious. These people should seek advice about drinking water from their health care providers. EPA/Canters for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosparidium and other microbial contaminants are available from the Safe Water Drinking Hotline (809-426-4791).

Where does my water come from? Our well draws from the Cockfeild aquifer,

Source water assessment and its availability

Our rating is moderate.

Why are there consaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Please contact our office with any questions or comments you may have.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Hinds Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at https://www.epa.gov/safewater-lead.

Additional Information for Finoride: To comply with the "regulations Governing Fluoridation of Community Water Supplies" NORTH HINDS W/A #6 Shepherds Hill required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were in the optimal range of 0.7-1.3 ppm was 0. The percentage of samples collected in the previous year that was within the optimal range of 0.7-1.3 ppm was 0.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

- 29		AMARIAN MANAGEMENT AND THE STREET		Chambiliorer (fore)		CARRIED AND AND AND AND AND AND AND AND AND AN					
	MCLG	MCL,									
	or-	TT, or	Your	Renge		Sample					
<u>Conteminants</u>	MRDLG	MRDL	Weter	Low	Hish	Desc	<u>Violetion</u>	Fyricel Source			
Disinfectants & Disinfectant By-Products											
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)											
Haloacetic Acids (HAA5) (ppb)	NA.	60	34	20	70	2014	No	By-product of drinking water chlorination			
TTHMs [Total Trihalomethanes] (ppb)	NA.	80	77.09	57	115.6	2014	No	By-product of drinking water disinfection			
Chlorine (as Cl2) (ppm)	4	4	0.6	0.5	8,0	2014	No	Water additive used to control microbes			
Inorgante Conteminants											
Bariun (ppm)	2	2	0.00284	NA		2012	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits			
Fluoride (ppm)	4	4	0.205	NA		2012	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories			
Unit Descriptions											
Ter	TA .		Definition								
ррі	ppm ·			ppm: parts per million, or milligrams per liter (mg/L)							
ppb			ppb: parts per billion, or micrograms per liter (μg/L)								
NA			NA: not applicable								
ND			ND: Not detected								
M	NR: Monitoring not required, but recommended.										
Important Drinking Wate	er Definitions		····		***************************************	-A+		Activities of the second secon			
Ter	Definition										
MCLG			MCLG; Maximum Contaminant Level Goal; The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.								
. мс	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.										
m	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.										
AI	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.										
Variances and	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.										
MRDLG			MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.								
MRI	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of nucrobial contaminants.										
MNR			MNR: Monitored Not Regulated								
MPL MPL: State Assigned Maximum Permissible Level							Permissible Level				

For more information please contact:

Confact Name: Doug Barker Address: P.O. Drawer 300 Flora, MS 39071 Phone: 6019811657 Fax: 6019811657